

THE DRAWING AND DESIGN HEREIN SHALL NOT BE DUPLICATED, USED OR REPRODUCED IN ANY MANNER FOR ANY PURPOSE WITHOUT THE WRITTEN PERMISSION OF HYT CORPORATION. HYT CORPORATION SHALL BEAR THE NOTICE.

REVISIONS

No.	Revision	By	Date	Appr.
1	BULLETIN 5	JPM	9/20/10	KW
2	RESPONSE TO HYT BULLETIN 5 REVIEW COMMENTS	JPM	10/19/10	KW
3	REVISED PER LBNL FIRE MARSHALS' COMMENTS	JPM	10/25/10	KW
4	AS-BUILT	JPM	9/20/12	KW

AS-BUILT

DESIGNER OF RECORD

DESIGNER OF RECORD

HYT Corporation
Fire Protection Engineers and Consultants
3499 Clayton Road - Suite 101 Concord, California 94519
Phone: (925) 681-2731 FAX: (925) 681-2733

INSTALLATION CONTRACTORS NAME & ADDRESS:

**W. BRADLEY
ELECTRIC, INC.**

90 Hill Road,
Novato, CA 94945

Tel (415) 898-1400 Fax (415) 898-5991

PRODUCT MANUFACTURER:

Siemens Industry, Inc.
Fire Safety Division

25821 Industrial Boulevard, Suite 300
Hayward, California 94545-2991
Tel (510) 783-6000 Fax (510) 283-2100
California State C10 License No. 758796
U.L. Certificate ID No. 324787-001

JOB NAME & LOCATION (STREET ADDRESS):

**UNIVERSITY OF CALIFORNIA
LAWRENCE BERKELEY NATIONAL LABORATORY
FACILITIES DIVISION**

**BUILDING 74
FIRE ALARM**

**LBNL SEISMIC
PHASE 2**

One Cyclotron Road,
Berkeley, California 94720

SHEET CONTENTS:

**FIRE ALARM PLAN -
FLOOR 1 (PROTECTOWIRE)**

INSTALLATION TYPE:

- ☐ NEW INSTALLATION
☐ DESIGN/BUILD
☐ PER CONTRACT DOCUMENT
☐ EXISTING BASE JOB # N/A
☐ OTHERS _____

SYSTEM SALES REP: Kevin Waxman

PROJECT MANAGER: Mark Millard

DRAWN BY: JPM

CAD FILENAME: FA-09

SCALE: 1/8" = 1'-0"

DATE DRAWN: March 16, 2010 PLOT DATE: March 27, 2014

DIRECT: FA-09A JOB NUMBER: 44OP-069681

SHEET NOTES:

- ALL FIRE ALARM EQUIPMENT AND PROTECTOWIRE ZONE BOXES SHALL BE PLACED IN A LOCATION SUCH THAT THEY ARE READILY ACCESSIBLE FOR MAINTENANCE AND TESTING. (TYPICAL TO ALL OPEN CEILING AREAS)
- FASTENERS SHOULD TYPICALLY BE SPACED EVERY 5-10 FEET, OR AS MAY BE NECESSARY TO PREVENT THE WIRE FROM SAGGING WHICH PUTS UNDUE STRESS ON THE WIRE AT THE FASTENING POINTS.

